



CITY OF LODI

COUNCIL COMMUNICATION

AGENDA TITLE: Plans and Specifications and Advertisement for Bids for
Poplar Street Wastewater Pipe Improvement, Cherokee Lane to
Central Avenue

MEETING DATE: July 15, 1992

PREPARED BY: Public Works Director

RECOMMENDED ACTION: That the City Council approve the plans and specifications for
the above project and authorize advertising for **bids**.

BACKGROUND INFORMATION: This project consists of jacking 95 lineal feet and
trenching approximately 1,800 lineal feet of 10-inch
diameter wastewater pipe parallel to the existing 8-inch
diameter wastewater pipe to improve the existing wastewater
flow and other incidental and related work, all as shown on the plans and
specifications for the project. The existing 8-inch diameter wastewater pipe will
be abandoned in place with control density fill upon the completion of the **new**
wastewater pipe.

The contractor will be given 36 working days to complete this project. During the
trenching operation, traffic on Poplar Street will be restricted to local use only.

FUNDING: Originally Budgeted: 1990
Budgeted Fund: Sewer Capital Outlay
Current Appropriation: \$159,000
Total Project Estimate: \$160,000
Bid Opening Date: August 12, 1992



Jack L. Ronsko
Public Works Director

Prepared by Lyman Chang, Assistant Engineer

JLR/LC/1m

cc: Purchasing Officer
Water/Wastewater Superintendent

APPROVED


THOMAS A. PETERSON
City Manager